

MINUTES OF PRE-BID CONFERENCE HELD AT LIOC TERMINAL TRINCOMALEE
ON 07-JUNE-2017

LIOC/ENG/PT/03/2017-18: PROVISION OF FALL ARREST SYSTEM IN TLF GANTRIES AND CALIBRATION TOWER AT LIOC TERMINAL TRINCOMALEE

Those Present:

LIOC

1. Mr. Sarawankanth, AM (Engg)

2. Mr. Yogeswaran, Exe (Engg)/ Trinco

Bidder's Representatives :


1. J.A. Chathura Kanishka, Industrial Safety Equipment

2. Mr. T.H Sajith Thushanka, Industrial Safety Equipment

3. Mr. R.A. Rajasuriya, Industrial Safety Equipment

The following queries were raised by the bidder.

S. No.	Query Raised	Response by LIOC
1	M/s. Industrial safety equipment: In clause 9 of "special terms & conditions of contract", responsibility for arranging required power has been mentioned in the scope of contractor.	LIOC responded that we will not arrange any power supply from Terminal. Contractor responsibility for arranging required power as per mentioned in the scope of contractor.
2	M/s. Industrial safety equipment: Whether it is possible to submit the work orders lesser amount than the qualifying parameter amounts.	LIOC conveyed that it must be tender qualifying parameters.
3	M/s. Industrial safety equipment: Whether NBT is payable under the taxes on LIOC account.	LIOC responded that in clause 10 of 'special terms & conditions of contract' VAT alone if payable shall be to LIOC account.
4	M/s. Industrial safety equipment: ISEC will give his own strength and stability certificate for all installation works.	LIOC conveyed that authorized TPI agency certify the entire installation.
5	M/s. Industrial safety equipment: Whether need to carry out any periodic inspections after the installation of fall arrest system.	LIOC conveyed that once in a year inspections should carry out on the fall arrest system. Cost will be negotiated with selected party. However All equipment including components and sub-contracted items should be guaranteed by the Vendor within the defect liability period mentioned in the tender.


En. Eng (Trinco)

MINUTES OF PRE-BID CONFERENCE HELD AT LIOC TERMINAL TRINCOMALEE


ON 07-JUNE-2017

LIOC/ENG/PT/03/2017-18: PROVISION OF FALL ARREST SYSTEM IN TLF GANTRIES AND CALIBRATION TOWER AT LIOC TERMINAL TRINCOMALEE

6	M/s. Industrial safety equipment: Any drawings need to submit along with technical bid.	LIOC conveyed that in the clause 2.2 under drawings & design requirements, fabrication drawing shall be prepared by the contractor and the same shall be approved by LIOC before commencement of work.
---	--	--



En. Engr - Trinco



ATTENDANCE - PRE BID MEETING FOR PROVISION OF ARRESTOR SYSTEM IN TLF GANTIES
& CALIBRATION TOWER CONDUCTED ON 07.06.2017

LANKA IOC

S.NO	NAME	COMPANY NAME	E-MAIL ID	TEL. NO.	SIGNATURE
1	T.H. Sasith Thushanka	TSEC	Sasith@Sasith.lk	0715354125	
2	J.A CHATHURA KANISHA	ISPC	chathura@getdata.lk	0718691758	
3	R.A Prasanna	JSTC	Arith Regunigala	0770293236	
4	T. yeggsun	LIOC	yeggsun@lanc.lk	0769208037	
5	K. Sarawananath	LIOC	Sarawananath@lanc.lk	0759278834	
6					
7					
8					
9					
10					
11					
12					
13					